

**Power Off!**  
**Challenges in Planning**  
**and Executing Power**  
**Isolations on Shared-Use**  
**Electrified Railways**

Paper 2023-101802  
Joint Rail Conference,  
Baltimore, Maryland

Alex Lu, Zhiqi Zhong  
*Metro-North Commuter Railroad*

Aleksandr Lukatskiy  
*Amtrak*

John G. Allen  
*Transportation Consultant*




March 26, 2023, 2<sup>nd</sup> draft

Electric railroads are fast, clean, safe, modern, noiseless, can reduce emissions, and be quite sustainable. Or at least we think so.




Yet investment decisions largely overlook the cost and complexity of maintaining the electric traction infrastructure after initial construction – especially after several decades when major elements need renewal or replacement.



On this National Historic Engineering Landmark, high-voltage alternating current overhead-electric railroad, it is a complex challenge keeping service operational while carrying out infrastructure maintenance and upgrades.






You are probably familiar with track outage planning and the trials and tribulations that it entails. On electrified railroads, it is necessary to plan power outages in conjunction with track outages, significantly increasing the complexity of planning.




An electrified railroad is a complex job site. Maintenance-of-Way personnel seek power isolations to perform routine inspections;






Class A Linemen protect Contractor work for electrical safety reasons; Substation Groundmen provide field grounds;



Dispatchers (or as we call them, “Rail Traffic Controllers”) implement track outages;  
Power Directors deliver the planned power isolations;



Conductor Flagmen protect Contractor work for track safety purposes; Support personnel erect “bridge plates” at stations ...





... or remove parts of the signal system from service.





All of this work ultimately depends on coordination of a team of highly skilled employees and contractors. Skilled labor is human. People get sick, have family emergencies, or can't get to work.



Marc A. Hermann / MTA photo (CC-BY 2.0)

Weather can play havoc with infrastructure, or require preparation that uses the same pool of skilled employees needed for the outage.





On-track machines can fail. Planned track outages might be cancelled at the last minute because of an unrelated emergency, like a switch machine getting stuck, a failed train, or a fire on the wayside.



Below is the proposed schedule for this weekend (6/29/18):

<i>Date</i>	<i>Project</i>	<i>Outage</i>	<i>Task</i>	<i>Priority</i>
(TBD) Friday (night) 6/29/18	(TBD) Verde: 14th Ave Bridge	(TBD) CP 212-215 Track 3 and north side	(TBD) Conduits	7
Friday (night) 6/29/18	MNR-Track: Undercutter	CP 217-223 Track 1 and 2	Undercutter work, Larchmont area	5
(TBD) Friday (night) 6/29/18	(TBD) MoW-Track: Soundbeach & Tomic	(TBD) CP 229-232 Track 1 and 2	(TBD) Bridge work	TBD

On Tuesdays, the Power department decides what work to cancel if there is a critical resource shortage. Contingency plans are drawn up, like Plan B if don't have enough personnel, Plan C if outages weren't approved, or Plan D if we have equipment failures.



**WEEKLY TRACK USAGE REQUEST**

Line	Day/Night	Track	Work Order	Work Description	Time	From	To	Mon	Tue	Wed	Thu	Fri	Sat	Sun	Remarks
NH	CONT.	3	CP233	CP233				A	A	A	A	A	A	A	
NH	CONT.	4	CP245	CP245				A	A	A	A	A	A	A	
NH	CONT.	2	CP257	CP257				A	A	A	A	A	A	A	
NH	CONT.	2	238	12K				A	A	A	A	A	A	A	
NH	CONT.	2	CP408	CP408				A	A	A	A	A	A	A	
NH	CONT.	1	CP408	CP408				A	A	A	A	A	A	A	
NH	DAY	5	CP255	CP255				A	A	A	A	A	A	A	
NH	DAY	6	CP257	CP257				A	A	A	A	A	A	A	
NH	DAY	3	CP257	CP257				A	A	A	A	A	A	A	
NH	DAY	4	CP257	CP257				A	A	A	A	A	A	A	
NH	NIGHT	3	CP257	CP257				A	A	A	A	A	A	A	
NH	NIGHT	4	CP257	CP257				A	A	A	A	A	A	A	
NH	NIGHT	4	CP257	CP257				A	A	A	A	A	A	A	
NH	NIGHT	3 OR 4	CP254	CP254				A	A	A	A	A	A	A	
NH	NIGHT	ALL	CP248	CP248				A	A	A	A	A	A	A	
NH	NIGHT	2	CP248	CP248				A	A	A	A	A	A	A	
NH	NIGHT	ALL	CP283	CP283				A	A	A	A	A	A	A	

**FLAGMAN SUPPORT REQUEST FORM**

Name: P. Scott

Project Name	Work Order #	Reporting Location	Work Description	Remarks
C1A-C2	20401	9	2nd 6 FARM	07:00
C1A-C2	20401	4	4th 6 FARM	20:00
C1A-C2	20401	3	3rd 6 FARM	
Green Bridge	20401	1	1st 6 FARM	
Green Bridge	20401	2	2nd 6 FARM	
CP 243	20502	3	3rd 6 FARM	07:00
Walk Bridge	20401	4	4th 6 FARM	07:00
Walk Bridge	20401	2	2nd 6 FARM	23:00

**Track Outage Request**

**Conductor Flag**

**Groundmen**

**4 Track Timeline**

**POWER DEPARTMENT**

DATE(S): Saturday 5/5/18

**PROJECT NAME:** Section C1-A / C2

**WORK ORDER NO.:** 20401 **LOCATION:** Gault Pad (Westport) **REPORT TIME:** 2200 hrs.

**CONTACT(S):** RE-ENERGIZE by: 0630 hrs.

**WORK SCHEDULE:** Bridge Ext. Removals/Westport Station Wire Removal

TIME	OUTAGE SCHEDULED	WORKING CLEARANCE	SPECIAL INSTRUCTIONS
2200 hrs.	South Side Power, #2, #4, #2, #4, #2	538 to 632	
2200 hrs.	Track 4 (four)	long term limits	long term outage
2330 hrs.	Track 1 (one)	538 to 632	
0030 hrs.	Track 2 (two)	538 to 632	
0115 hrs.	Track 3 (three)	538 to 632	
0115 hrs.	North Side Feeders P1, P3 & C1	538 to 632	signal remain energized

**NOTES:**

- 1) All times are subject to change.
- 2) Track 3 is the Running Track, all ground signals.
- 3) Catenary Foreman will be present.
- 4) North side signals remain energized for outage.
- 5) No Substation Request

**FAX NUMBERS:**

POWER DIRECTOR: 4599 (Wong/Walsh/Papillon)

POWER DIRECTOR: FAX 2858 (Campbell) 2289

CATENARY: 411444115 (Anderson) 3666 (Roberts)

SUBSTATIONS: 2652 (Santoro) (Tarnowski) 4204

HAKS: 263 353-6265

TRANSPORTATION: (Frankie) 5771/N 2828/D (Davies) 2889

INSPECTORS: (Balsano) 4116 / (Pond) 3795

DOUCI: Clear 263-576 6856

On Wednesdays, requests go out to other areas to get track time, Flagmen, Linemen, Groundmen, and Power Directors. Supervisors in each area account for regular maintenance workloads, and commit resources only when not needed elsewhere.

TAR = TRACK AS REQUESTED  
A = AMBULANCE CONTINGENCY  
S = AS MUCH TIME AS POSSIBLE

# APPROVED WEEKLY AUTHORIZED TRACK USAGE

Metro-North Railroad

Line: New Haven													
#	Track	From	To	Work Done	From	To	Fri	Sat	Sun	Mon	Tue	Wed	Thur
YANKEES/NYCTC SCHEDULE													
DAY													
1	TAR	New Haven	-	Line	TRACK PATROL	0001	-	2359	X	X	X	X	X
2	TAR	CP 212	-	CP 271	WIRE TRUCK / PLASSER	0930	-	1530	X		X	X	X
3	2	CP 217	-	CP 223	UNDERCUTTER / TIMBERS MAMARONECK AVE	CONT	A	A	A	A	A	A	A
4	TAR	CP 217	-	CP 255	UNDERCUTTER UNLOAD SPOILS	1000	-	1600	X		X	X	X
5	1	CP 229	-	CP 232	SOUNDREACH/TOMAC/COR BRIDGE WORK	CONT	A	A	A	A	A	A	A
6	2	CP 229	-	CP 232	SOUNDREACH/TOMAC/COR BRIDGE WORK	1000	-	1500	X		X	X	X
7	2	CP 229	-	CP 232	SOUNDREACH/TOMAC/COR BRIDGE WORK	0700	-	1500	X	X			
8	4	CP 241	-	CP 248	CATENARY C1A WIRE CONTRACTOR / NHL TIE GANG	CONT	A	A	A	A	A	A	A
9	2	CP 241	-	CP 248	CATENARY C1A WIRE AND CP 243 CONTRACTORS / NHL TIE GANG	CONT	A	A	A				A
10	1	CP 255	-	CP 261	CATENARY C2 WIRE CONTRACTOR / MUDSPOT REMEDIATION	0915	-	1600	X		X	X	X
11	2	CP 255	-	CP 257	CATENARY C2 WIRE CONTRACTOR	CONT	A	A	A	A	A	A	A
12	2	CP 257	-	CP 261	CATENARY C2 WIRE CONTRACTOR	CONT	A	A	A	A	A	A	A
13	2	CP 261	-	CP 261	CATENARY C2 WIRE CONTRACTOR / DEVON BRIDGE WORK	CONT	A	A	A	A	A	A	A
14	TAR	CP 261	-	CP 271	POTWELD / CLEANUP / REPLACE US / SPOT SURFACE	0930	-	1500	X		X	X	X
15	5, 3 & 1	CP 271	-	CP 273	REPLACE 318 SWITCH @ CP 272, TREE TRIMMERS	CONT							A
NIGHT													
1	3 & 1	CP 212	-	CP 235	14TH AVE BRIDGE CONTRACTORS	0135	-	0500		X	X	X	X
2	4 & 1	CP 217	-	CP 223	UNDERCUTTER WORK TRACKS	2330	-	0800	X	X	X	X	X
3	4	CP 223	-	CP 229	PAINT WESTCHESTER BRIDGE	0915	-	0600	X	X			X
4	4 & 2	CP 223	-	CP 232	SIGNAL CONTRACTORS / TREE TRIMMERS	0115	-	0600	X	X	X	X	X
5	TAR	CP 232	-	CP 272	POWER DEPT. PLASSER/WIRE TRUCK, POWER DEPT. INTERLOCKING AND DRAWBRIDGE INSPECTION	0030	-	0530	X	X	X	X	X
6	4 & 2	CP 233	-	CP 234	ATLANTIC STREET CONTRACTORS	2359	-	0530	X	X	X	X	X
7	4 & 2	CP 234	-	CP 240	PTC CONTRACTOR	0045	-	0530					X
8	ALL	CP 241	-	CP 248	SUBSTATION / CP 243 / C1A CONTRACTORS	0630	-	0615	X				
9	3 & 1	CP 241	-	CP 248	REPLACE RAIL / TIE STUB CLEANUP / MUDSPOT REMEDIATION	0030	-	0600			X	X	

On Thursdays, the track outage conference takes place and the Dispatching Chiefs decide whether outages will be granted.

**METRO-NORTH POWER DEPARTMENT  
OUTAGE REQUESTED / CLASS 'A' ASSIGNMENT**


										2017	DATE:	6/22 to 6/24	
LINE	NIGHT WEEKEND			WORK	COST	NUMBER	CLASS A MEN	VEHICLE(S)	OUTAGE	REPORT			
NO.	DESCRIPTION	LOCATION	PC	ORDER	CENTER	OF DAYS	ASSIGNED	ASSIGNED	REQUESTED	TIME	REMARKS	CHECK	
1	POWER DEPT.	SPRINGDALE	061		35009	1	JONES		POWER AS REQUEST	22:00	SUN		
2	POWER DEPT.	BRIDGEPORT	061		35009	2	ROMANOFF		POWER AS REQUEST	22:00	FRI, SAT		
3	UNDERCUTTER	LARCHMONT	061	81139	35171	2	TWO		TR 2 E80A-W184	22:00	FRI, SAT	*	
4	WALK BRIDGE PROJECT	NORWALK	061	20550	32242	3	ROBADO JAMES TWO(SU)	SUB 537	TR 3 E524-W537 NORTH SIDE E527-W537	22:00	FRI, SAT, SUN	*	
5	CIA DUCCI	EAST NORWALK	061	20401	35411	2	TWO	SUB 537	TR 3 E531-W532 TR 1 E531-W532 NORTH SIDE E524-W532	22:00	FRI, SAT	*	
6	RIZZO NETWORKING	BRIDGEPORT BURR ROAD	061	29526	35411	2	SCHMIDT(FR) ONE(FR) TWO(SA)		TR 3 635-735 NORTH SIDE E65-W735	20:00	FRI, SAT	*	
7	UI BAIRD TO CONGRESS	BRIDGEPORT	061	52112	35571	2	BRIDGEPORT GANG	SUB 814	4 TRACK OUTAGE SEE TIMELINE	21:00	FRI, SAT	*	
8	BRIDGEPORT TRACK	DEVON	061		35610	1	BRIDGEPORT GANG		TR 2 E858-W184A	22:00	FRI	*	
9	RIZZO SUBSTATION 885	DEVON	061	20276	35610	2	BRIDGEPORT GANG		TR 3 & 1 NORTH SIDE (LIMITS OF 4 TRACK OUTAGE)	22:00	FRI, SAT	*	
10	SPECIAL PROJECTS	NEW HAVEN CP272 31 SWITCH	061	20472	35720	1	SKREBIS ONE		TR 3 E1050B-W1068 TR 1 E1053-W1081	22:00	FRI	*	
11	NH DRILLERS	NEW HAVEN	061	20021	35720	1	TWO		TR 1 E1081-W1087	21:00	FRI	*	
12	ATLANTIC STREET	STAMFORD	061	20492	35340	2	TWO		TR 4 E356B-W372A TR 2 E366A-W371A	22:00	SAT, SUN	*	
13	14TH AVE VERDE	MT. VERNON	061	12160	35121	1	ASZMUS CHIBOLM		NORTH SIDE WEST OF 23	22:00	SUN	*	
14	NH LINE SIGNAL PROJECT VERDE	NOROTON HEIGHTS	061	20511	35341	1	TWO		TR 4 E374-W513A SOUTH SIDE E374-W524	22:00	SUN	*	
15	NH LINE SIGNAL PROJECT TREE TRIMMERS	RIVERSIDE	061	20511	35291	1	TWO		TR 4 E295A-W356B TR 2 E298A-W354A SOUTH SIDE E313-W374	22:00	SUN	*	
16	UI / McPHEE BAIRD TO CONGRESS	BRIDGEPORT	061	52112	35571	1	TWO	SUB 814	TR 4 E774-W DEVON SOUTH SIDE E775A-W867 (shorten limits as needed)	22:00	SUN	*	

On Friday is when the real-time factors, like labor shortages, equipment malfunctions, severe weather, or unexpected operational incidents will be definitively knowable. Although fraught with points requiring short-notice revisions, this process works well if all stakeholders actively support the process and are fully engaged.






Most rail professionals have some experience with routing trains around a track obstruction, making moves using appropriate signals, crossovers, and tracks. Isolating a segment of overhead catenary is similar in concept, but outages must provide electrical paths to deliver power outside the de-energized area, keep crossovers and drawbridges energized whenever possible, and ensure that the power supply doesn't become "unbalanced".



By placing six motorized disconnects (or MODs) around an universal interlocking, we can keep the crossovers live even when a middle track needs to be isolated.



The catenaries within the interlocking can essentially be fed from either end. However, this adds to the circuit complexity and complicates switching operations.





Substations are not typically located at interlocking locations. Interlocking locations are based on train service needs and physical site characteristics ...



... whereas substation locations are based on power demand constraints, electrical resistance considerations, supply convenience, and space needs. This introduces additional circuit complexity to accommodate substation switching requirements.

Section C1A-C2				START: 7/2/18	Finish: 7/21/18				
DATE	TIME	WORK LIMITS	SUB NAME	PROTECTIVE SERVICES	TASK DESCRIPTION	CREW SIZE	EQUIPMENT	SUBMITTAL/WORK PLAN	Remarks
7/2/18 (Monday Night)	22:00 to 06:00	C1A	Quadr	2 Flagman 2 Groundmen	Drop Tube Installation	1 crew	2 Buckets 1 Pulled	Approved	Track 2 SS
7/2/18-28/18	07:00-18:00	C1A	Quadr	7 Flagman 4 Groundmen 5 Mechanic	Wire Install Drop Tube Install Steel Repair Wire Removal	6 Crews		Approved	Track 4 Long Term C-2 Track 1 CP257, Track 1 & 2
	07:00-1			2 Flagman	Foundation Repair	2 Crews		Approved	Track 4 RCMV
7/7/18 (Saturday)	07:00-			Foundation Mechanic	3-3 Repeater and inspect S35A Track 2 Jumper Complete S35A Jumper Run Aerial Ground (S35-S38)	3 Crews	5 Buckets Platform	Approved	Track 2
7/7/18 (Saturday Night)	23:00 to			2 Groundmen				Approved	K5 Power 4 Track Cuts, Track 2 Running
7/8/18-21/18	07:00 to 18:00	C1A/C2	Quadr	7 Flagman 4 Groundmen 5 Mechanic	Wire Install Drop Tube Install Steel Repair Wire Removal	6 Crews		Approved	Track 4 Southside Anchor Bridge 814 Track 1 (C1A) (C2)-CP257 Tracks 1 & 2 CP261
	07:00-18:00	C1A/C2	NYCDOT	2 Flagman	Foundation Repair	2 Crews		Approved	Track 4 RCMV
7/7-18 (Wednesday Night)	22:00 to 06:00	C2	Quadr	4 Flagman 2 Groundmen	Wire Install	2 Crews	1 Pulled	Approved	(C2)-Track 4 & 2 CP261 Southside Power
7/13/18 (Friday Night)	22:00 to 06:00			4 Flagman 2 Groundmen	C2 Trolley Installation	3 Crews	5 Buckets Platform	Approved	C-2 Track 4 & 2 CP261 Southside Power
7/18/18 (Saturday Night)	22:00 to 06:00							Approved	
7/18/18 to 7/22/18	07:00 to 18:00	C1A	Quadr	7 Flagman 4 Groundmen 5 Mechanic	Wire Install Drop Tube Install Steel Repair Wire Removal	6 Crews	6 Buckets	Approved	Track 4 Long Term Southside Power Anchor Bridge 537
	07:00-18:00	C3	Quadr	1 Flagman	C3 Snow Miter	1 Crew		Approved	
	07:00-18:00	C1A/C2	NYCDOT	2 Flagman	Foundation Repair	2 Crews		Approved	Track 4 RCMV
7/18/18 (Wednesday Night)	22:00 to 06:00	C1A/C2	Quadr	2 Flagman 2 Groundmen	C2 Trolley	2 crew	2 Buckets 1 Pulled	Approved	Track 4 (C2) Track 2 (C1A)
7/25/18 (Friday Night)	22:00 to 06:00			4 Flagman 2 Groundmen	TSD	2 Crews	3 Buckets	Approved	C-2 Track 4 SS
7/27/18 (Saturday)	07:00-18:00	C1A	Quadr	4 Flagman 2 Groundmen	TSD	2 Crews	3 Buckets	Approved	

A high degree of customization is required to configure circuits for wire work at any given location. Work on the same track and the same signal block a few catenaries apart on two consecutive nights may have entirely different electrical and mechanical environments, and may require a different circuit set-up to provide the necessary isolation. Each outage in effect requires a tailor-made circuit configuration and must be meticulously planned by Power Directors responsible for switching operations.






The actions of Power Directors and Dispatchers at the same physical locations must line up. Where the catenary is grounded for an outage, the signals and switches must be set such that no electric trains enter the segment.




Some equipment have multiple pantographs bussed together. Allowing an electric train to travel across an air gap or section insulator between energized and de-energized sections momentarily allows two sections to be electrically connected, resulting in backfeeding through the high voltage bus onboard the train.




To ensure safe operations, we use Plate Orders, which are pre-defined limits showing track segments that cannot be used for electric operations, and identify switches that must be blocked unless required by a diesel train. Typically, the area having electric operations barred (from switch to switch) is slightly larger than segments of catenary being isolated (from SI to SI), as a safety backstop.






Typically, to accomplish a circuit change, four steps are necessary. First, the request is received from the Field. The change is then commanded via SCADA or paperwork. Then an employee will execute the change, whether by operating an in-line knife switch, motoring an MOD, racking out a breaker, or attaching grounds. The device is then tagged out to prevent resetting in error. For a fully remote-controlled device, this sequence may take only 30 to 90 seconds. However, where physical operations are necessary in the Field, it will take longer.




These (conceptual) steps are needed to isolate a segment of catenary:




(1) Open appropriate breakers at all substations within the section.






(2) Operate MODs or in-line switches with power de-energized to reduce outage limits.




(3) If adjacent sections become de-energized as a consequence, close appropriate switches to provide backfeed.




(4) If there's a substation in the dead section, open breakers and apply system grounds.






(5) Install grounds. If aerial grounds are used, more de-energizing may be needed to allow safe access.



(6) When everything is set up, the entire area is re-energized by closing the substation breakers.




(7) Test for potential within the outage, and install box grounds.





How many circuit changes does it take to implement a typical outage? We have an example where an outage across all four tracks was necessary to remove bridge wires. One anchor bridge (awaiting final decommissioning), one malfunctioning substation, and one movable river bridge all fall within the outage limits.




It is not unusual to find these “obstructions” while trying to set up an outage. Six forms were needed, one for each track and one each for feeder line groups on either side of the right-of-way, which together required 78 individual operations to be commanded.




How long does this all take? We measured this on a typical night of operations, and found that the longest delay was actually caused by overrunning service due to trains from an afternoon baseball game affecting the overnight work window.





Once track outages became effective, it was fairly fast to run through all the necessary steps, but because of their complexity, even under near-ideal conditions with proper planning, it still took one hour and 51 minutes to accomplish this. Factor in the time required to restore the power before the morning rush, that six-hour overnight work window can quickly become a two-and-a-half-hour work window. That, ladies and gentlemen, is the fundamental reason why catenary renewals under traffic always seem to take longer than generally thought.




While track layout is the domain of the civil engineer, where the priorities are track speed, capacity, and safety ...




... power infrastructure is designed by the electrical engineer where the concerns are cost, load capability, and safety. When possible, interlockings and traction substations could be co-located, or at least designed jointly, to simplify maintenance and emergency power isolations.






Personnel with a solid understanding of both electrical and track infrastructure and processes are vital in both planning and construction. Typically, Transportation, Track, and Power are different departments, but cross-training is possible with agreements and promotional paths that facilitate the acquisition of such knowledge.







Overlapping isolations are particularly disruptive when two outages overlap but do not begin and end at the same time, requiring re-configuration of circuits four times that weekend:



... for outage A, ...




... for outages A and B together, ...



... for outage B, ...






... and to clear up.




The trade-off between piggybacking work to spread the costs of alternative service and construction support, and the increased risks and complexity that come with overlapping outages, should be carefully considered.



Maximum maintenance outage capacity should be assessed formally, separately for track and power infrastructure. There exists a maximum practical operational capacity to provide track and power outages while maintaining train service, which is something that may not be fully appreciated. This “outage capacity” should be assessed formally, similar to how track signaling capacity is assessed now.





MTA Capital Construction photo (CC-BY 2.0)

The benefits of electric traction are most evident in high-density, high-utilization corridors, but ongoing maintenance can impose significant costs. These “hassle” factors help explain why U.S. railroads have historically preferred diesel traction.





However, with the recent advent of high-capacity battery-electric locomotives that can haul typical loads over a 200-mile gap in electric catenary, electrification may now be possible over a wide area while concentrating electric traction infrastructure in the highest density segments, re-charging the locomotives in motion.



If you'll now think twice before wiring up every track mile, then I've done my job for today.

**Any Questions?  
Discussion? Comments?**

Author contact information:

Alex Lu  
P.O. Box 684  
Ossining, N.Y. 10562-0684  
[Lu@mnr.org](mailto:Lu@mnr.org)  
(978) 361-0528

Zhiqi Zhong  
[Zhong@mnr.org](mailto:Zhong@mnr.org)

Aleksandr Lukatskiy  
[Aleksandr.Lukatskiy@amtrak.com](mailto:Aleksandr.Lukatskiy@amtrak.com)

John G. Allen  
[jgatransit@2200.com](mailto:jgatransit@2200.com)



Thank you!